

Water Quality Tests Results (Heiwa-machi)

No.	Items	Heiwa-machi						Unit
		24/4/2019	22/5/2019	25/6/2019	3/7/2019	8/8/2019	12/9/2019	
	Water temperature	11.8	16.5	17.9	19.8	23.2	24.4	(°C)
1	Common Bacteria	0	0	0	0	0	0	(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	(MPN/100mL)
3	Cadmium							(mg/L)
4	Mercury							(mg/L)
5	Selenium							(mg/L)
6	Lead			< 0.001			< 0.001	(mg/L)
7	Arsenic							(mg/L)
8	Chromium (VI)	< 0.005			< 0.005			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			< 0.001	(mg/L)
11	Nitrate and Nitrite	0.4	0.3	0.3	0.3	0.3	0.4	(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride			< 0.0002			< 0.0002	(mg/L)
15	1, 4-dioxane							(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2-Dichloroethylene			< 0.004			< 0.004	(mg/L)
17	Dichloromethane			< 0.002			< 0.002	(mg/L)
18	Tetrachloroethylene			< 0.001			< 0.001	(mg/L)
19	Trichloroethylene			< 0.001			< 0.001	(mg/L)
20	Benzene			< 0.001			< 0.001	(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06	< 0.06	0.08	< 0.06	(mg/L)
22	Chloroacetic acid			< 0.002			< 0.002	(mg/L)
23	Chloroform			0.005			0.007	(mg/L)
24	Dichloroacetic acid			< 0.003			0.004	(mg/L)
25	Dibromochloromethane			< 0.001			< 0.001	(mg/L)
26	Bromate			< 0.001			< 0.001	(mg/L)
27	Total trihalomethanes			0.008			0.010	(mg/L)
28	Trichloroacetic acid			0.003			0.005	(mg/L)
29	Bromodichloromethane			0.002			0.003	(mg/L)
30	Bromoform			< 0.001			< 0.001	(mg/L)
31	Formaldehyde			< 0.008			< 0.008	(mg/L)
32	Zinc			< 0.01			< 0.01	(mg/L)
33	Aluminium	< 0.01	< 0.01	< 0.01	< 0.01	0.01	< 0.01	(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	(mg/L)
36	Sodium	4.0	3.6	3.9	4.1	4.7	4.7	(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	(mg/L)
38	Chloride ion	4.6	3.5	3.7	3.7	3.7	3.7	(mg/L)
39	Calcium, Magnesium (Hardness)	22	22	21	20	26	25	(mg/L)
40	Total residue	34			53			(mg/L)
41	Anionic surface active agent							(mg/L)
42	Geosmin			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
43	2-Methylisobornol			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
44	Nonionic surface active agent							(mg/L)
45	Phenols							(mg/L)
46	Organic substances (Total Organic Carbon)	< 0.3	< 0.3	0.4	0.5	0.5	0.6	(mg/L)
47	pH Value	7.5	7.4	7.3	7.3	7.4	7.4	
48	Taste	None	None	None	None	None	None	
49	Odor	None	None	None	None	None	None	
50	Color	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	(degree)
51	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	(degree)
	Free residual chlorine ※2	0.46	0.46	0.46	0.50	0.56	0.52	(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine \geq 0.1 mg/L

Water Quality Tests Results (Heiwa-machi)

No.	Items	Heiwa-machi					Unit
		31/10/2019					
	Water temperature	15.0					(°C)
1	Common Bacteria	0					(number/mL)
2	E.coli	N.D. ※1					(MPN/100mL)
3	Cadmium						(mg/L)
4	Mercury						(mg/L)
5	Selenium						(mg/L)
6	Lead						(mg/L)
7	Arsenic						(mg/L)
8	Chromium (VI)	< 0.005					(mg/L)
9	Nitrite nitrogen	< 0.004					(mg/L)
10	Cyanide ion and Cyanogens chloride						(mg/L)
11	Nitrate and Nitrite	0.4					(mg/L)
12	Fluoride	< 0.08					(mg/L)
13	Boron						(mg/L)
14	Carbon tetrachloride						(mg/L)
15	1, 4-dioxane						(mg/L)
16	<i>cis</i> -1,2-Dichloroethylene and <i>trans</i> -1,2-Dichloroethylene						(mg/L)
17	Dichloromethane						(mg/L)
18	Tetrachloroethylene						(mg/L)
19	Trichloroethylene						(mg/L)
20	Benzene						(mg/L)
21	Chlorate	< 0.06					(mg/L)
22	Chloroacetic acid						(mg/L)
23	Chloroform						(mg/L)
24	Dichloroacetic acid						(mg/L)
25	Dibromochloromethane						(mg/L)
26	Bromate						(mg/L)
27	Total trihalomethanes						(mg/L)
28	Trichloroacetic acid						(mg/L)
29	Bromodichloromethane						(mg/L)
30	Bromoform						(mg/L)
31	Formaldehyde						(mg/L)
32	Zinc						(mg/L)
33	Aluminium	< 0.01					(mg/L)
34	Iron	< 0.03					(mg/L)
35	Copper	< 0.01					(mg/L)
36	Sodium	4.8					(mg/L)
37	Manganese	< 0.001					(mg/L)
38	Chloride ion	4.3					(mg/L)
39	Calcium, Magnesium (Hardness)	25					(mg/L)
40	Total residue	46					(mg/L)
41	Anionic surface active agent						(mg/L)
42	Geosmin	< 0.000001					(mg/L)
43	2-Methylisobolneol	< 0.000001					(mg/L)
44	Nonionic surface active agent						(mg/L)
45	Phenols						(mg/L)
46	Organic substances (Total Organic Carbon)	0.4					(mg/L)
47	pH Value	7.4					
48	Taste	None					
49	Odor	None					
50	Color	< 0.5					(degree)
51	Turbidity	< 0.1					(degree)
	Free residual chlorine ※2	0.40					(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine \geq 0.1 mg/L