

Water Quality Tests Results (Tsuchishimizu)

No.	Items	Tsuchishimizu						Unit
		24/4/2019	22/5/2019	25/6/2019	3/7/2019	8/8/2019	12/9/2019	
	Water temperature	14.1	17.0	21.0	21.8	26.9	25.6	(°C)
1	Common Bacteria	0	0	0	0	0	0	(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	(MPN/100mL)
3	Cadmium							(mg/L)
4	Mercury							(mg/L)
5	Selenium							(mg/L)
6	Lead			< 0.001			< 0.001	(mg/L)
7	Arsenic							(mg/L)
8	Chromium (VI)	< 0.005			< 0.005			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			< 0.001	(mg/L)
11	Nitrate and Nitrite	0.4	0.3	0.3	0.3	0.3	0.4	(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride			< 0.0002			< 0.0002	(mg/L)
15	1, 4-dioxane							(mg/L)
16	cis -1,2-Dichloroethylene and trans -1,2- Dichloroethylene			< 0.004			< 0.004	(mg/L)
17	Dichloromethane			< 0.002			< 0.002	(mg/L)
18	Tetrachloroethylene			< 0.001			< 0.001	(mg/L)
19	Trichloroethylene			< 0.001			< 0.001	(mg/L)
20	Benzene			< 0.001			< 0.001	(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06	< 0.06	0.07	< 0.06	(mg/L)
22	Chloroacetic acid			< 0.002			< 0.002	(mg/L)
23	Chloroform			0.011			0.016	(mg/L)
24	Dichloroacetic acid			0.006			0.006	(mg/L)
25	Dibromochloromethane			< 0.001			< 0.001	(mg/L)
26	Bromate			< 0.001			< 0.001	(mg/L)
27	Total trihalomethanes			0.015			0.021	(mg/L)
28	Trichloroacetic acid			0.005			0.008	(mg/L)
29	Bromodichloromethane			0.004			0.004	(mg/L)
30	Bromoform			< 0.001			< 0.001	(mg/L)
31	Formaldehyde			< 0.008			< 0.008	(mg/L)
32	Zinc			< 0.01			< 0.01	(mg/L)
33	Aluminium	< 0.01	< 0.01	< 0.01	< 0.01	0.01	< 0.01	(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	(mg/L)
35	Copper	0.02	< 0.01	0.02	0.01	0.02	0.02	(mg/L)
36	Sodium	4.0	3.6	3.9	4.2	4.6	4.8	(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	(mg/L)
38	Chloride ion	4.3	3.5	3.6	3.8	3.7	3.9	(mg/L)
39	Calcium, Magnesium (Hardness)	22	22	21	22	25	24	(mg/L)
40	Total residue	34			47			(mg/L)
41	Anionic surface active agent							(mg/L)
42	Geosmin			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
43	2-Methylisobolneol			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
44	Nonionic surface active agent							(mg/L)
45	Phenols							(mg/L)
46	Organic substances (Total Organic Carbon)	< 0.3	< 0.3	0.5	0.4	0.5	0.6	(mg/L)
47	pH Value	7.5	7.5	7.4	7.4	7.5	7.5	
48	Taste	None	None	None	None	None	None	
49	Odor	None	None	None	None	None	None	
50	Color	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	(degree)
51	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	(degree)
	Free residual chlorine ※2	0.36	0.40	0.30	0.38	0.36	0.40	(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine $\geq$ 0.1 mg/L

Water Quality Tests Results (Tsuchishimizu)

No.	Items	Tsuchishimizu						Unit
		31/10/2019						
	Water temperature	16.8						(°C)
1	Common Bacteria	0						(number/mL)
2	E.coli	N.D. ※1						(MPN/100mL)
3	Cadmium							(mg/L)
4	Mercury							(mg/L)
5	Selenium							(mg/L)
6	Lead							(mg/L)
7	Arsenic							(mg/L)
8	Chromium (VI)	< 0.005						(mg/L)
9	Nitrite nitrogen	< 0.004						(mg/L)
10	Cyanide ion and Cyanogens chloride							(mg/L)
11	Nitrate and Nitrite	0.4						(mg/L)
12	Fluoride	< 0.08						(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride							(mg/L)
15	1, 4-dioxane							(mg/L)
16	cis -1,2-Dichloroethylene and trans -1,2- Dichloroethylene							(mg/L)
17	Dichloromethane							(mg/L)
18	Tetrachloroethylene							(mg/L)
19	Trichloroethylene							(mg/L)
20	Benzene							(mg/L)
21	Chlorate	< 0.06						(mg/L)
22	Chloroacetic acid							(mg/L)
23	Chloroform							(mg/L)
24	Dichloroacetic acid							(mg/L)
25	Dibromochloromethane							(mg/L)
26	Bromate							(mg/L)
27	Total trihalomethanes							(mg/L)
28	Trichloroacetic acid							(mg/L)
29	Bromodichloromethane							(mg/L)
30	Bromoform							(mg/L)
31	Formaldehyde							(mg/L)
32	Zinc							(mg/L)
33	Aluminium	< 0.01						(mg/L)
34	Iron	< 0.03						(mg/L)
35	Copper	0.01						(mg/L)
36	Sodium	4.8						(mg/L)
37	Manganese	< 0.001						(mg/L)
38	Chloride ion	4.3						(mg/L)
39	Calcium, Magnesium (Hardness)	25						(mg/L)
40	Total residue	46						(mg/L)
41	Anionic surface active agent							(mg/L)
42	Geosmin	< 0.000001						(mg/L)
43	2-Methylisoborneol	< 0.000001						(mg/L)
44	Nonionic surface active agent							(mg/L)
45	Phenols							(mg/L)
46	Organic substances (Total Organic Carbon)	0.4						(mg/L)
47	pH Value	7.5						
48	Taste	None						
49	Odor	None						
50	Color	< 0.5						(degree)
51	Turbidity	< 0.1						(degree)
	Free residual chlorine ※2	0.40						(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥ 0.1 mg/L