

Water Quality Tests Results
(Purified Water of Sue Water Purification Plant (Rapid sand filtration method))

No.	Items	Purified Water of Sue Water Purification Plant (Rapid sand filtration method)						Unit
		19/4/2019	28/5/2019	11/6/2019	8/7/2019	21/8/2019	4/9/2019	
	Water temperature	8.4	13.7	15.1	16.0	17.2	18.8	(°C)
1	Common Bacteria	0	0	0	0	0	0	(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	(MPN/100mL)
3	Cadmium		< 0.0003			< 0.0003		(mg/L)
4	Mercury		< 0.00005			< 0.00005		(mg/L)
5	Selenium	< 0.001			< 0.001			(mg/L)
6	Lead			< 0.001			< 0.001	(mg/L)
7	Arsenic	< 0.001			< 0.001			(mg/L)
8	Chromium (VI)	< 0.005			< 0.005			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			< 0.001	(mg/L)
11	Nitrate and Nitrite	0.4	0.2	0.3	0.3	0.4	0.3	(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	(mg/L)
13	Boron			< 0.1			< 0.1	(mg/L)
14	Carbon tetrachloride			< 0.0002			< 0.0002	(mg/L)
15	1, 4-dioxane	< 0.005			< 0.005			(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene			< 0.004			< 0.004	(mg/L)
17	Dichloromethane			< 0.002			< 0.002	(mg/L)
18	Tetrachloroethylene			< 0.001			< 0.001	(mg/L)
19	Trichloroethylene			< 0.001			< 0.001	(mg/L)
20	Benzene			< 0.001			< 0.001	(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06	0.08	0.06	0.07	(mg/L)
22	Chloroacetic acid							(mg/L)
23	Chloroform			0.003			0.003	(mg/L)
24	Dichloroacetic acid							(mg/L)
25	Dibromochloromethane			< 0.001			< 0.001	(mg/L)
26	Bromate			< 0.001			< 0.001	(mg/L)
27	Total trihalomethanes			0.004			0.005	(mg/L)
28	Trichloroacetic acid							(mg/L)
29	Bromodichloromethane			0.001			0.002	(mg/L)
30	Bromoform			< 0.001			< 0.001	(mg/L)
31	Formaldehyde							(mg/L)
32	Zinc			< 0.01			< 0.01	(mg/L)
33	Aluminium	< 0.01	0.02	0.02	0.02	0.02	0.03	(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	(mg/L)
36	Sodium	4.4	4.1	4.7	5.1	6.5	5.8	(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	(mg/L)
38	Chloride ion	6.3	4.1	4.8	5.2	6.2	5.9	(mg/L)
39	Calcium, Magnesium (Hardness)	23	23	25	23	28	21	(mg/L)
40	Total residue	42			54			(mg/L)
41	Anionic surface active agent	< 0.02			< 0.02			(mg/L)
42	Geosmin			0.000002	< 0.000001	0.000001	< 0.000001	(mg/L)
43	2-Methylisoborneol			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
44	Nonionic surface active agent	< 0.005			< 0.005			(mg/L)
45	Phenols		< 0.0005			< 0.0005		(mg/L)
46	Organic substances (Total Organic Carbon)	< 0.3	0.3	0.4	0.4	0.5	0.5	(mg/L)
47	pH Value	7.3	7.3	7.3	7.3	7.4	7.4	
48	Taste	None	None	None	None	None	None	
49	Odor	None	None	None	None	None	None	
50	Color	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	(degree)
51	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	(degree)
	Free residual chlorine ※2	0.54	0.58	0.62	0.66	0.68	0.78	(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥ 0.1 mg/L

Water Quality Tests Results

(Purified Water of Sue Water Purification Plant (Rapid sand filtration method))

No.	Items	Purified Water of Sue Water Purification Plant (Rapid sand filtration method)						Unit
		24/10/2019	21/11/2019	4/12/2019	9/1/2020			
	Water temperature	13.8	9.4	8.6	6.9			(°C)
1	Common Bacteria	0	0	0	0			(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1			(MPN/100mL)
3	Cadmium		< 0.0003					(mg/L)
4	Mercury		< 0.00005					(mg/L)
5	Selenium	< 0.001			< 0.001			(mg/L)
6	Lead			< 0.001				(mg/L)
7	Arsenic	< 0.001			< 0.001			(mg/L)
8	Chromium (VI)	< 0.005			< 0.005			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004			(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001				(mg/L)
11	Nitrate and Nitrite	0.4	0.4	0.4	0.4			(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08			(mg/L)
13	Boron			< 0.1				(mg/L)
14	Carbon tetrachloride			< 0.0002				(mg/L)
15	1, 4-dioxane	< 0.005			< 0.005			(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene			< 0.004				(mg/L)
17	Dichloromethane			< 0.002				(mg/L)
18	Tetrachloroethylene			< 0.001				(mg/L)
19	Trichloroethylene			< 0.001				(mg/L)
20	Benzene			< 0.001				(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06	< 0.06			(mg/L)
22	Chloroacetic acid							(mg/L)
23	Chloroform			0.002				(mg/L)
24	Dichloroacetic acid							(mg/L)
25	Dibromochloromethane			< 0.001				(mg/L)
26	Bromate			< 0.001				(mg/L)
27	Total trihalomethanes			0.004				(mg/L)
28	Trichloroacetic acid							(mg/L)
29	Bromodichloromethane			0.001				(mg/L)
30	Bromoform			< 0.001				(mg/L)
31	Formaldehyde							(mg/L)
32	Zinc			< 0.01				(mg/L)
33	Aluminium	0.02	0.02	0.01	0.01			(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03	< 0.03			(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01			(mg/L)
36	Sodium	5.4	5.0	5.2	5.6			(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001	< 0.001			(mg/L)
38	Chloride ion	6.3	6.4	7.0	8.9			(mg/L)
39	Calcium, Magnesium (Hardness)	24	26	26	23			(mg/L)
40	Total residue	39			48			(mg/L)
41	Anionic surface active agent	< 0.02			< 0.02			(mg/L)
42	Geosmin	< 0.000001	< 0.000001					(mg/L)
43	2-Methylisoborneol	< 0.000001	< 0.000001					(mg/L)
44	Nonionic surface active agent	< 0.005			< 0.005			(mg/L)
45	Phenols		< 0.0005					(mg/L)
46	Organic substances (Total Organic Carbon)	0.4	0.5	0.3	< 0.3			(mg/L)
47	pH Value	7.4	7.3	7.4	7.3			
48	Taste	None	None	None	None			
49	Odor	None	None	None	None			
50	Color	< 0.5	< 0.5	< 0.5	< 0.5			(degree)
51	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1			(degree)
	Free residual chlorine ※2	0.54	0.50	0.70	0.54			(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥ 0.1 mg/L