

Water Quality Tests Results
(Purified Water of Sue Water Purification Plant (Slow sand filtration method))

No.	Items	Purified Water of Sue Water Purification Plant (Slow sand filtration method)					Unit
		23/4/2020	26/5/2020	16/6/2020			
	Water temperature	9.3	16.7	20.0			(°C)
1	Common Bacteria	2	3	3			(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1			(MPN/100mL)
3	Cadmium		< 0.0003				(mg/L)
4	Mercury		< 0.00005				(mg/L)
5	Selenium	< 0.001					(mg/L)
6	Lead			< 0.001			(mg/L)
7	Arsenic	< 0.001					(mg/L)
8	Chromium (VI)	< 0.002					(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004			(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			(mg/L)
11	Nitrate and Nitrite	0.4	0.3	0.4			(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08			(mg/L)
13	Boron			< 0.1			(mg/L)
14	Carbon tetrachloride			< 0.0002			(mg/L)
15	1, 4-dioxane	< 0.005					(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2-Dichloroethylene			< 0.004			(mg/L)
17	Dichloromethane			< 0.002			(mg/L)
18	Tetrachloroethylene			< 0.001			(mg/L)
19	Trichloroethylene			< 0.001			(mg/L)
20	Benzene			< 0.001			(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06			(mg/L)
22	Chloroacetic acid						(mg/L)
23	Chloroform			< 0.001			(mg/L)
24	Dichloroacetic acid						(mg/L)
25	Dibromochloromethane			< 0.001			(mg/L)
26	Bromate			< 0.001			(mg/L)
27	Total trihalomethanes			0.001			(mg/L)
28	Trichloroacetic acid						(mg/L)
29	Bromodichloromethane			< 0.001			(mg/L)
30	Bromoform			< 0.001			(mg/L)
31	Formaldehyde						(mg/L)
32	Zinc			< 0.01			(mg/L)
33	Aluminium	< 0.01	< 0.01	< 0.01			(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03			(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01			(mg/L)
36	Sodium	3.9	3.9	4.5			(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001			(mg/L)
38	Chloride ion	4.0	2.9	4.0			(mg/L)
39	Calcium, Magnesium (Hardness)	23	25	30			(mg/L)
40	Total residue	26					(mg/L)
41	Anionic surface active agent	< 0.02					(mg/L)
42	Geosmin			< 0.000001			(mg/L)
43	2-Methylisoborneol			< 0.000001			(mg/L)
44	Nonionic surface active agent	< 0.005					(mg/L)
45	Phenols		< 0.0005				(mg/L)
46	Organic substances (Total Organic Carbon)	0.4	0.3	0.6			(mg/L)
47	pH Value	7.6	7.4	7.3			
48	Taste	None	None	None			
49	Odor	None	None	None			
50	Color	1	< 0.5	< 0.5			(degree)
51	Turbidity	< 0.1	< 0.1	< 0.1			(degree)
	Free residual chlorine ※2	0.48	0.58	0.62			(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine \geq 0.1 mg/L

Water Quality Tests Results
(Purified Water of Sue Water Purification Plant (Slow sand filtration method))

No.	Items	Purified Water of Sue Water Purification Plant (Slow sand filtration method)						Unit
	Water temperature							(°C)
1	Common Bacteria							(number/mL)
2	E.coli							(MPN/100mL)
3	Cadmium							(mg/L)
4	Mercury							(mg/L)
5	Selenium							(mg/L)
6	Lead							(mg/L)
7	Arsenic							(mg/L)
8	Chromium (VI)							(mg/L)
9	Nitrite nitrogen							(mg/L)
10	Cyanide ion and Cyanogens chloride							(mg/L)
11	Nitrate and Nitrite							(mg/L)
12	Fluoride							(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride							(mg/L)
15	1, 4-dioxane							(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene							(mg/L)
17	Dichloromethane							(mg/L)
18	Tetrachloroethylene							(mg/L)
19	Trichloroethylene							(mg/L)
20	Benzene							(mg/L)
21	Chlorate							(mg/L)
22	Chloroacetic acid							(mg/L)
23	Chloroform							(mg/L)
24	Dichloroacetic acid							(mg/L)
25	Dibromochloromethane							(mg/L)
26	Bromate							(mg/L)
27	Total trihalomethanes							(mg/L)
28	Trichloroacetic acid							(mg/L)
29	Bromodichloromethane							(mg/L)
30	Bromoform							(mg/L)
31	Formaldehyde							(mg/L)
32	Zinc							(mg/L)
33	Aluminium							(mg/L)
34	Iron							(mg/L)
35	Copper							(mg/L)
36	Sodium							(mg/L)
37	Manganese							(mg/L)
38	Chloride ion							(mg/L)
39	Calcium, Magnesium (Hardness)							(mg/L)
40	Total residue							(mg/L)
41	Anionic surface active agent							(mg/L)
42	Geosmin							(mg/L)
43	2-Methylisoborneol							(mg/L)
44	Nonionic surface active agent							(mg/L)
45	Phenols							(mg/L)
46	Organic substances (Total Organic Carbon)							(mg/L)
47	pH Value							
48	Taste							
49	Odor							
50	Color							(degree)
51	Turbidity							(degree)
	Free residual chlorine ※2							(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥ 0.1 mg/L