

Water Quality Tests Results (Magae)

No.	Items	Magae						Unit
		24-Apr-2023	10-May-2023	28-Jun-2023	12-Jul-2023			
	Water temperature	14.6	17.7	23.4	25.4			(°C)
1	Common Bacteria	< 1	< 1	< 1	< 1			(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1			(MPN/100mL)
3	Cadmium							(mg/L)
4	Mercury							(mg/L)
5	Selenium							(mg/L)
6	Lead			< 0.001				(mg/L)
7	Arsenic							(mg/L)
8	Chromium (VI)	< 0.002			< 0.002			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004			(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001				(mg/L)
11	Nitrate and Nitrite	0.3	0.3	0.2	0.2			(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08			(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride			< 0.0002				(mg/L)
15	1, 4-dioxane							(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene			< 0.004				(mg/L)
17	Dichloromethane			< 0.002				(mg/L)
18	Tetrachloroethylene			< 0.001				(mg/L)
19	Trichloroethylene			< 0.001				(mg/L)
20	Benzene			< 0.001				(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06	< 0.06			(mg/L)
22	Chloroacetic acid			< 0.002				(mg/L)
23	Chloroform			0.017				(mg/L)
24	Dichloroacetic acid			< 0.003				(mg/L)
25	Dibromochloromethane			0.001				(mg/L)
26	Bromate			< 0.001				(mg/L)
27	Total trihalomethanes			0.025				(mg/L)
28	Trichloroacetic acid			0.009				(mg/L)
29	Bromodichloromethane			0.006				(mg/L)
30	Bromoform			< 0.001				(mg/L)
31	Formaldehyde			< 0.008				(mg/L)
32	Zinc			< 0.01				(mg/L)
33	Aluminium	0.03	0.02	0.06	0.08			(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03	< 0.03			(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01			(mg/L)
36	Sodium	3.9	4.3	5.4	4.8			(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001	< 0.001			(mg/L)
38	Chloride ion	4.6	6.3	5.1	4.6			(mg/L)
39	Calcium, Magnesium (Hardness)	23	23	26	26			(mg/L)
40	Total residue	53			78			(mg/L)
41	Anionic surface active agent							(mg/L)
42	Geosmin			< 0.000001	< 0.000001			(mg/L)
43	2-Methylisobolneol			< 0.000001	< 0.000001			(mg/L)
44	Nonionic surface active agent							(mg/L)
45	Phenols							(mg/L)
46	Organic substances (Total Organic Carbon)	< 0.3	< 0.3	0.4	0.6			(mg/L)
47	pH Value	7.5	7.4	7.6	7.5			
48	Taste	None	None	None	None			
49	Odor	None	None	None	None			
50	Color	< 0.5	< 0.5	< 0.5	< 0.5			(degree)
51	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1			(degree)
	Free residual chlorine ※2	0.36	0.38	0.32	0.34			(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥ 0.1 mg/L