

Water Quality Tests Results (Shimoyasuhara-machi)

| No. | Items | Shimoyasuhara-machi | | | | | Unit |
|-----|---|---------------------|-------------|-------------|-------------|--|-------------|
| | | 30-Apr-2024 | 16-May-2024 | 26-Jun-2024 | 10-Jul-2024 | | |
| | Water temperature | 16.6 | 18.6 | 24.0 | 24.1 | | (°C) |
| 1 | Common Bacteria | < 1 | < 1 | < 1 | < 1 | | (number/mL) |
| 2 | E.coli | N.D. ※1 | N.D. ※1 | N.D. ※1 | N.D. ※1 | | (MPN/100mL) |
| 3 | Cadmium | | | | | | (mg/L) |
| 4 | Mercury | | | | | | (mg/L) |
| 5 | Selenium | | | | | | (mg/L) |
| 6 | Lead | | | < 0.001 | | | (mg/L) |
| 7 | Arsenic | | | | | | (mg/L) |
| 8 | Chromium (VI) | < 0.002 | | | < 0.002 | | (mg/L) |
| 9 | Nitrite nitrogen | < 0.004 | < 0.004 | < 0.004 | < 0.004 | | (mg/L) |
| 10 | Cyanide ion and Cyanogens chloride | | | < 0.001 | | | (mg/L) |
| 11 | Nitrate and Nitrite | 0.2 | 0.2 | 0.1 | 0.2 | | (mg/L) |
| 12 | Fluoride | < 0.08 | < 0.08 | < 0.08 | < 0.08 | | (mg/L) |
| 13 | Boron | | | | | | (mg/L) |
| 14 | Carbon tetrachloride | | | < 0.0002 | | | (mg/L) |
| 15 | 1, 4-dioxane | | | | | | (mg/L) |
| 16 | cis-1,2-Dichloroethylene and trans-1,2-Dichloroethylene | | | < 0.004 | | | (mg/L) |
| 17 | Dichloromethane | | | < 0.002 | | | (mg/L) |
| 18 | Tetrachloroethylene | | | < 0.001 | | | (mg/L) |
| 19 | Trichloroethylene | | | < 0.001 | | | (mg/L) |
| 20 | Benzene | | | < 0.001 | | | (mg/L) |
| 21 | Chlorate | < 0.06 | 0.06 | 0.06 | < 0.06 | | (mg/L) |
| 22 | Chloroacetic acid | | | < 0.002 | | | (mg/L) |
| 23 | Chloroform | | | 0.018 | | | (mg/L) |
| 24 | Dichloroacetic acid | | | 0.003 | | | (mg/L) |
| 25 | Dibromochloromethane | | | 0.001 | | | (mg/L) |
| 26 | Bromate | | | < 0.001 | | | (mg/L) |
| 27 | Total trihalomethanes | | | 0.024 | | | (mg/L) |
| 28 | Trichloroacetic acid | | | 0.011 | | | (mg/L) |
| 29 | Bromodichloromethane | | | 0.005 | | | (mg/L) |
| 30 | Bromoform | | | < 0.001 | | | (mg/L) |
| 31 | Formaldehyde | | | < 0.008 | | | (mg/L) |
| 32 | Zinc | | | < 0.01 | | | (mg/L) |
| 33 | Aluminium | 0.03 | 0.04 | 0.04 | 0.05 | | (mg/L) |
| 34 | Iron | < 0.03 | < 0.03 | < 0.03 | < 0.03 | | (mg/L) |
| 35 | Copper | < 0.01 | < 0.01 | < 0.01 | < 0.01 | | (mg/L) |
| 36 | Sodium | 4.3 | 4.2 | 5.2 | 4.6 | | (mg/L) |
| 37 | Manganese | < 0.001 | < 0.001 | < 0.001 | < 0.001 | | (mg/L) |
| 38 | Chloride ion | 3.9 | 4.1 | 6.1 | 4.2 | | (mg/L) |
| 39 | Calcium, Magnesium (Hardness) | 26 | 27 | 26 | 23 | | (mg/L) |
| 40 | Total residue | 45 | | | 39 | | (mg/L) |
| 41 | Anionic surface active agent | | | | | | (mg/L) |
| 42 | Geosmin | | | < 0.000001 | < 0.000001 | | (mg/L) |
| 43 | 2-Methylisobolneol | | | < 0.000001 | < 0.000001 | | (mg/L) |
| 44 | Nonionic surface active agent | | | | | | (mg/L) |
| 45 | Phenols | | | | | | (mg/L) |
| 46 | Organic substances (Total Organic Carbon) | < 0.3 | < 0.3 | 0.3 | 0.5 | | (mg/L) |
| 47 | pH Value | 7.6 | 7.6 | 7.5 | 7.6 | | |
| 48 | Taste | None | None | None | None | | |
| 49 | Odor | None | None | None | None | | |
| 50 | Color | < 0.5 | < 0.5 | < 0.5 | < 0.5 | | (degree) |
| 51 | Turbidity | < 0.1 | < 0.1 | < 0.1 | < 0.1 | | (degree) |
| | Free residual chlorine ※2 | 0.46 | 0.38 | 0.40 | 0.30 | | (mg/L) |

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥ 0.1 mg/L