

Water Quality Tests Results (Source Water of Sue Water Purification Plant)

No.	Items	Source Water of Sue Water Purification Plant					Unit
		24-Apr-2024	23-May-2024	19-Jun-2024	23-Jul-2024		
	Water temperature	11.6	13.5	17.1	18.0		(°C)
1	Common Bacteria	9	4	21	230		(number/mL)
2	E.coli	26	4.1	5.2	180		(MPN/100mL)
3	Cadmium		< 0.0003				(mg/L)
4	Mercury		< 0.00005				(mg/L)
5	Selenium	< 0.001			< 0.001		(mg/L)
6	Lead			< 0.001			(mg/L)
7	Arsenic	< 0.001			0.001		(mg/L)
8	Chromium (VI)	< 0.002			< 0.002		(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004		(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			(mg/L)
11	Nitrate and Nitrite	0.2	0.2	0.2	0.2		(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08		(mg/L)
13	Boron			< 0.1			(mg/L)
14	Carbon tetrachloride			< 0.0002			(mg/L)
15	1, 4-dioxane	< 0.005			< 0.005		(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2-Dichloroethylene			< 0.004			(mg/L)
17	Dichloromethane			< 0.002			(mg/L)
18	Tetrachloroethylene			< 0.001			(mg/L)
19	Trichloroethylene			< 0.001			(mg/L)
20	Benzene			< 0.001			(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06	< 0.06		(mg/L)
22	Chloroacetic acid						(mg/L)
23	Chloroform			< 0.001			(mg/L)
24	Dichloroacetic acid						(mg/L)
25	Dibromochloromethane			< 0.001			(mg/L)
26	Bromate			< 0.001			(mg/L)
27	Total trihalomethanes			< 0.001			(mg/L)
28	Trichloroacetic acid						(mg/L)
29	Bromodichloromethane			< 0.001			(mg/L)
30	Bromoform			< 0.001			(mg/L)
31	Formaldehyde						(mg/L)
32	Zinc			< 0.01			(mg/L)
33	Aluminium	0.07	0.03	0.04	1.8		(mg/L)
34	Iron	0.03	< 0.03	0.04	0.54		(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01		(mg/L)
36	Sodium	3.3	3.9	4.7	3.5		(mg/L)
37	Manganese	0.004	0.007	0.018	0.019		(mg/L)
38	Chloride ion	3.0	2.7	3.1	2.2		(mg/L)
39	Calcium, Magnesium (Hardness)	20	24	30	21		(mg/L)
40	Total residue	44			34		(mg/L)
41	Anionic surface active agent	< 0.02			< 0.02		(mg/L)
42	Geosmin			< 0.000001	0.000001		(mg/L)
43	2-Methylisoborneol			< 0.000001	< 0.000001		(mg/L)
44	Nonionic surface active agent	< 0.005			< 0.005		(mg/L)
45	Phenols		< 0.0005				(mg/L)
46	Organic substances (Total Organic Carbon)	0.4	0.5	0.5	1.4		(mg/L)
47	pH Value	7.5	7.6	7.4	7.3		
48	Taste						
49	Odor	None	None	None	None		
50	Color	2	2	3	17		(degree)
51	Turbidity	2.0	1.2	1.6	37		(degree)
	Free residual chlorine						(mg/L)

※1 N.D. = Not detected