

Water Quality Tests Results (Sainen)

No.	Items	Sainen						Unit
		30-Apr-2024	16-May-2024	26-Jun-2024	10-Jul-2024	20-Aug-2024	18-Sep-2024	
	Water temperature	13.2	14.1	19.8	19.9	22.8	23.1	(°C)
1	Common Bacteria	< 1	< 1	< 1	< 1	< 1	< 1	(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	(MPN/100mL)
3	Cadmium							(mg/L)
4	Mercury							(mg/L)
5	Selenium							(mg/L)
6	Lead			< 0.001			< 0.001	(mg/L)
7	Arsenic							(mg/L)
8	Chromium (VI)	< 0.002			< 0.002			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			< 0.001	(mg/L)
11	Nitrate and Nitrite	0.2	0.2	0.2	0.2	0.2	0.3	(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride			< 0.0002			< 0.0002	(mg/L)
15	1, 4-dioxane							(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2-Dichloroethylene			< 0.004			< 0.004	(mg/L)
17	Dichloromethane			< 0.002			< 0.002	(mg/L)
18	Tetrachloroethylene			< 0.001			< 0.001	(mg/L)
19	Trichloroethylene			< 0.001			< 0.001	(mg/L)
20	Benzene			< 0.001			< 0.001	(mg/L)
21	Chlorate	< 0.06	0.06	< 0.06	< 0.06	< 0.06	0.06	(mg/L)
22	Chloroacetic acid			< 0.002			< 0.002	(mg/L)
23	Chloroform			0.014			0.028	(mg/L)
24	Dichloroacetic acid			0.003			0.004	(mg/L)
25	Dibromochloromethane			< 0.001			< 0.001	(mg/L)
26	Bromate			< 0.001			< 0.001	(mg/L)
27	Total trihalomethanes			0.019			0.040	(mg/L)
28	Trichloroacetic acid			0.009			0.017	(mg/L)
29	Bromodichloromethane			0.004			0.009	(mg/L)
30	Bromoform			< 0.001			< 0.001	(mg/L)
31	Formaldehyde			< 0.008			< 0.008	(mg/L)
32	Zinc			< 0.01			< 0.01	(mg/L)
33	Aluminium	0.03	0.03	0.04	0.05	0.07	0.11	(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	(mg/L)
36	Sodium	4.4	3.9	5.2	4.7	5.8	7.2	(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	(mg/L)
38	Chloride ion	4.3	3.6	5.5	4.7	4.5	6.7	(mg/L)
39	Calcium, Magnesium (Hardness)	21	25	26	24	31	28	(mg/L)
40	Total residue	41			28			(mg/L)
41	Anionic surface active agent							(mg/L)
42	Geosmin			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
43	2-Methylisoborneol			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
44	Nonionic surface active agent							(mg/L)
45	Phenols							(mg/L)
46	Organic substances (Total Organic Carbon)	< 0.3	< 0.3	0.3	0.5	0.5	0.7	(mg/L)
47	pH Value	7.5	7.4	7.4	7.5	7.6	7.6	
48	Taste	None	None	None	None	None	None	
49	Odor	None	None	None	None	None	None	
50	Color	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	(degree)
51	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	(degree)
	Free residual chlorine ※2	0.44	0.42	0.46	0.44	0.56	0.42	(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine \geq 0.1 mg/L

Water Quality Tests Results (Sainen)

No.	Items	Sainen					Unit
		24-Oct-2024					
	Water temperature	17.3					(°C)
1	Common Bacteria	< 1					(number/mL)
2	E.coli	N.D. ※1					(MPN/100mL)
3	Cadmium						(mg/L)
4	Mercury						(mg/L)
5	Selenium						(mg/L)
6	Lead						(mg/L)
7	Arsenic						(mg/L)
8	Chromium (VI)	< 0.002					(mg/L)
9	Nitrite nitrogen	< 0.004					(mg/L)
10	Cyanide ion and Cyanogens chloride						(mg/L)
11	Nitrate and Nitrite	0.2					(mg/L)
12	Fluoride	< 0.08					(mg/L)
13	Boron						(mg/L)
14	Carbon tetrachloride						(mg/L)
15	1, 4-dioxane						(mg/L)
16	<small>cis-1,2-Dichloroethylene and trans-1,2-Dichloroethylene</small>						(mg/L)
17	Dichloromethane						(mg/L)
18	Tetrachloroethylene						(mg/L)
19	Trichloroethylene						(mg/L)
20	Benzene						(mg/L)
21	Chlorate	< 0.06					(mg/L)
22	Chloroacetic acid						(mg/L)
23	Chloroform						(mg/L)
24	Dichloroacetic acid						(mg/L)
25	Dibromochloromethane						(mg/L)
26	Bromate						(mg/L)
27	Total trihalomethanes						(mg/L)
28	Trichloroacetic acid						(mg/L)
29	Bromodichloromethane						(mg/L)
30	Bromoform						(mg/L)
31	Formaldehyde						(mg/L)
32	Zinc						(mg/L)
33	Aluminium	0.05					(mg/L)
34	Iron	< 0.03					(mg/L)
35	Copper	< 0.01					(mg/L)
36	Sodium	7.1					(mg/L)
37	Manganese	< 0.001					(mg/L)
38	Chloride ion	6.8					(mg/L)
39	Calcium, Magnesium (Hardness)	32					(mg/L)
40	Total residue	74					(mg/L)
41	Anionic surface active agent						(mg/L)
42	Geosmin	< 0.000001					(mg/L)
43	2-Methylisobolneol	< 0.000001					(mg/L)
44	Nonionic surface active agent						(mg/L)
45	Phenols						(mg/L)
46	Organic substances (Total Organic Carbon)	0.4					(mg/L)
47	pH Value	7.7					
48	Taste	None					
49	Odor	None					
50	Color	< 0.5					(degree)
51	Turbidity	< 0.1					(degree)
	Free residual chlorine ※2	0.52					(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥ 0.1 mg/L