

# Water Quality Tests Results

## (Purified Water of Saigawa Water Purification Plant)

| No. | Items                                                    | Purified Water of Saigawa Water Purification Plant |             |  |  |  |  | Unit        |
|-----|----------------------------------------------------------|----------------------------------------------------|-------------|--|--|--|--|-------------|
|     |                                                          | 23-Apr-2025                                        | 29-May-2025 |  |  |  |  |             |
|     | Water temperature                                        | 10.3                                               | 11.0        |  |  |  |  | ( °C )      |
| 1   | Common Bacteria                                          | < 1                                                | 1           |  |  |  |  | (number/mL) |
| 2   | E.coli                                                   | N.D. ※1                                            | N.D. ※1     |  |  |  |  | (MPN/100mL) |
| 3   | Cadmium                                                  |                                                    | < 0.0003    |  |  |  |  | (mg/L)      |
| 4   | Mercury                                                  |                                                    | < 0.00005   |  |  |  |  | (mg/L)      |
| 5   | Selenium                                                 | < 0.001                                            |             |  |  |  |  | (mg/L)      |
| 6   | Lead                                                     |                                                    |             |  |  |  |  | (mg/L)      |
| 7   | Arsenic                                                  | < 0.001                                            |             |  |  |  |  | (mg/L)      |
| 8   | Chromium (VI)                                            | < 0.002                                            |             |  |  |  |  | (mg/L)      |
| 9   | Nitrite nitrogen                                         | < 0.004                                            | < 0.004     |  |  |  |  | (mg/L)      |
| 10  | Cyanide ion and Cyanogens chloride                       |                                                    |             |  |  |  |  | (mg/L)      |
| 11  | Nitrate and Nitrite                                      | 0.3                                                | 0.2         |  |  |  |  | (mg/L)      |
| 12  | Fluoride                                                 | < 0.08                                             | < 0.08      |  |  |  |  | (mg/L)      |
| 13  | Boron                                                    |                                                    |             |  |  |  |  | (mg/L)      |
| 14  | Carbon tetrachloride                                     |                                                    |             |  |  |  |  | (mg/L)      |
| 15  | 1, 4-dioxane                                             | < 0.005                                            |             |  |  |  |  | (mg/L)      |
| 16  | cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene |                                                    |             |  |  |  |  | (mg/L)      |
| 17  | Dichloromethane                                          |                                                    |             |  |  |  |  | (mg/L)      |
| 18  | Tetrachloroethylene                                      |                                                    |             |  |  |  |  | (mg/L)      |
| 19  | Trichloroethylene                                        |                                                    |             |  |  |  |  | (mg/L)      |
| 20  | Benzene                                                  |                                                    |             |  |  |  |  | (mg/L)      |
| 21  | Chlorate                                                 | < 0.06                                             | < 0.06      |  |  |  |  | (mg/L)      |
| 22  | Chloroacetic acid                                        |                                                    |             |  |  |  |  | (mg/L)      |
| 23  | Chloroform                                               |                                                    |             |  |  |  |  | (mg/L)      |
| 24  | Dichloroacetic acid                                      |                                                    |             |  |  |  |  | (mg/L)      |
| 25  | Dibromochloromethane                                     |                                                    |             |  |  |  |  | (mg/L)      |
| 26  | Bromate                                                  |                                                    |             |  |  |  |  | (mg/L)      |
| 27  | Total trihalomethanes                                    |                                                    |             |  |  |  |  | (mg/L)      |
| 28  | Trichloroacetic acid                                     |                                                    |             |  |  |  |  | (mg/L)      |
| 29  | Bromodichloromethane                                     |                                                    |             |  |  |  |  | (mg/L)      |
| 30  | Bromoform                                                |                                                    |             |  |  |  |  | (mg/L)      |
| 31  | Formaldehyde                                             |                                                    |             |  |  |  |  | (mg/L)      |
| 32  | Zinc                                                     |                                                    |             |  |  |  |  | (mg/L)      |
| 33  | Aluminium                                                | 0.01                                               | 0.02        |  |  |  |  | (mg/L)      |
| 34  | Iron                                                     | < 0.03                                             | < 0.03      |  |  |  |  | (mg/L)      |
| 35  | Copper                                                   | < 0.01                                             | < 0.01      |  |  |  |  | (mg/L)      |
| 36  | Sodium                                                   | 6.4                                                | 6.1         |  |  |  |  | (mg/L)      |
| 37  | Manganese                                                | < 0.001                                            | < 0.001     |  |  |  |  | (mg/L)      |
| 38  | Chloride ion                                             | 7.9                                                | 6.5         |  |  |  |  | (mg/L)      |
| 39  | Calcium, Magnesium (Hardness)                            | 14                                                 | 17          |  |  |  |  | (mg/L)      |
| 40  | Total residue                                            | 37                                                 |             |  |  |  |  | (mg/L)      |
| 41  | Anionic surface active agent                             | < 0.02                                             |             |  |  |  |  | (mg/L)      |
| 42  | Geosmin                                                  |                                                    |             |  |  |  |  | (mg/L)      |
| 43  | 2-Methylisobolneol                                       |                                                    |             |  |  |  |  | (mg/L)      |
| 44  | Nonionic surface active agent                            | < 0.005                                            |             |  |  |  |  | (mg/L)      |
| 45  | Phenols                                                  |                                                    | < 0.0005    |  |  |  |  | (mg/L)      |
| 46  | Organic substances (Total Organic Carbon)                | < 0.3                                              | < 0.3       |  |  |  |  | (mg/L)      |
| 47  | pH Value                                                 | 7.3                                                | 7.3         |  |  |  |  |             |
| 48  | Taste                                                    | None                                               | None        |  |  |  |  |             |
| 49  | Odor                                                     | None                                               | None        |  |  |  |  |             |
| 50  | Color                                                    | < 0.5                                              | < 0.5       |  |  |  |  | ( degree )  |
| 51  | Turbidity                                                | < 0.1                                              | < 0.1       |  |  |  |  | ( degree )  |
|     | Free residual chlorine ※2                                | 0.58                                               | 0.54        |  |  |  |  | (mg/L)      |

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine  $\geq 0.1$  mg/L