

Water Quality Tests Results (Shimoyasuhara-machi)

No.	Items	Shimoyasuhara-machi						Unit
		30-Apr-2025	14-May-2025	24-Jun-2025	16-Jul-2025	27-Aug-2025		
	Water temperature	15.7	16.6	23.1	25.6	28.0		(°C)
1	Common Bacteria	< 1	< 1	< 1	< 1	< 1		(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1		(MPN/100mL)
3	Cadmium							(mg/L)
4	Mercury							(mg/L)
5	Selenium							(mg/L)
6	Lead			< 0.001				(mg/L)
7	Arsenic							(mg/L)
8	Chromium (VI)	< 0.002			< 0.002			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004		(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001				(mg/L)
11	Nitrate and Nitrite	0.3	0.2	0.2	0.2	0.2		(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08		(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride			< 0.0002				(mg/L)
15	1, 4-dioxane							(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2-Dichloroethylene			< 0.004				(mg/L)
17	Dichloromethane			< 0.002				(mg/L)
18	Tetrachloroethylene			< 0.001				(mg/L)
19	Trichloroethylene			< 0.001				(mg/L)
20	Benzene			< 0.001				(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06		(mg/L)
22	Chloroacetic acid			< 0.002				(mg/L)
23	Chloroform			0.013				(mg/L)
24	Dichloroacetic acid			< 0.003				(mg/L)
25	Dibromochloromethane			< 0.001				(mg/L)
26	Bromate			< 0.001				(mg/L)
27	Total trihalomethanes			0.018				(mg/L)
28	Trichloroacetic acid			0.008				(mg/L)
29	Bromodichloromethane			0.005				(mg/L)
30	Bromoform			< 0.001				(mg/L)
31	Formaldehyde			< 0.008				(mg/L)
32	Zinc			< 0.01				(mg/L)
33	Aluminium	0.02	0.02	0.03	0.04	0.06		(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03		(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01		(mg/L)
36	Sodium	4.1	3.8	3.9	4.5	5.0		(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001		(mg/L)
38	Chloride ion	4.9	5.5	4.6	5.3	5.0		(mg/L)
39	Calcium, Magnesium (Hardness)	20	19	24	21	23		(mg/L)
40	Total residue	46			43			(mg/L)
41	Anionic surface active agent							(mg/L)
42	Geosmin			< 0.000001	< 0.000001	< 0.000001		(mg/L)
43	2-Methylisoborneol			< 0.000001	< 0.000001	< 0.000001		(mg/L)
44	Nonionic surface active agent							(mg/L)
45	Phenols							(mg/L)
46	Organic substances (Total Organic Carbon)	< 0.3	< 0.3	0.3	0.4	0.4		(mg/L)
47	pH Value	7.6	7.5	7.5	7.6	7.7		
48	Taste	None	None	None	None	None		
49	Odor	None	None	None	None	None		
50	Color	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5		(degree)
51	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1		(degree)
	Free residual chlorine ※2	0.30	0.42	0.20	0.36	0.28		(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥ 0.1 mg/L