

Water Quality Tests Results

(Source Water of Sue Water Purification Plant)

No.	Items	Source Water of Sue Water Purification Plant						Unit
		23-Apr-2025	29-May-2025	18-Jun-2025	9-Jul-2025	20-Aug-2025		
	Water temperature	8.6	11.2	13.7	17.9	19.0		(°C)
1	Common Bacteria	9	15	35	280	55		(number/mL)
2	E.coli	2.0	12	50	390	5.2		(MPN/100mL)
3	Cadmium		< 0.0003			< 0.0003		(mg/L)
4	Mercury		< 0.00005			< 0.00005		(mg/L)
5	Selenium	< 0.001			< 0.001			(mg/L)
6	Lead			< 0.001				(mg/L)
7	Arsenic	< 0.001			0.001			(mg/L)
8	Chromium (VI)	< 0.002			< 0.002			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004		(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001				(mg/L)
11	Nitrate and Nitrite	0.3	0.2	0.2	0.5	0.4		(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08		(mg/L)
13	Boron			< 0.1				(mg/L)
14	Carbon tetrachloride			< 0.0002				(mg/L)
15	1, 4-dioxane	< 0.005			< 0.005			(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene			< 0.004				(mg/L)
17	Dichloromethane			< 0.002				(mg/L)
18	Tetrachloroethylene			< 0.001				(mg/L)
19	Trichloroethylene			< 0.001				(mg/L)
20	Benzene			< 0.001				(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06		(mg/L)
22	Chloroacetic acid							(mg/L)
23	Chloroform			< 0.001				(mg/L)
24	Dichloroacetic acid							(mg/L)
25	Dibromochloromethane			< 0.001				(mg/L)
26	Bromate			< 0.001				(mg/L)
27	Total trihalomethanes			< 0.001				(mg/L)
28	Trichloroacetic acid							(mg/L)
29	Bromodichloromethane			< 0.001				(mg/L)
30	Bromoform			< 0.001				(mg/L)
31	Formaldehyde							(mg/L)
32	Zinc			< 0.01				(mg/L)
33	Aluminium	0.13	0.16	0.36	0.10	0.20		(mg/L)
34	Iron	0.06	0.07	0.11	0.08	0.12		(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01		(mg/L)
36	Sodium	3.1	2.8	2.8	3.8	3.8		(mg/L)
37	Manganese	0.005	0.010	0.071	0.013	0.016		(mg/L)
38	Chloride ion	3.6	2.5	2.3	2.8	2.6		(mg/L)
39	Calcium, Magnesium (Hardness)	15	17	17	23	23		(mg/L)
40	Total residue	27			23			(mg/L)
41	Anionic surface active agent	< 0.02			< 0.02			(mg/L)
42	Geosmin			< 0.000001	0.000001	< 0.000001		(mg/L)
43	2-Methylisobolneol			< 0.000001	< 0.000001	< 0.000001		(mg/L)
44	Nonionic surface active agent	< 0.005			< 0.005			(mg/L)
45	Phenols		< 0.0005			< 0.0005		(mg/L)
46	Organic substances (Total Organic Carbon)	0.5	0.8	1.2	1.1	1.2		(mg/L)
47	pH Value	7.4	7.5	7.3	7.4	7.3		
48	Taste							
49	Odor	None	None	None	None	None		
50	Color	3	3	6	6	7		(degree)
51	Turbidity	4.3	4.0	9.2	3.9	3.9		(degree)
	Free residual chlorine							(mg/L)

※1 N.D. = Not detected