

Water Quality Tests Results

(Purified Water of Shijima-naka Water Distribution Plant)

No.	Items	Purified Water of Shijima-naka Water Distribution Plant						Unit
		23-Apr-2025	29-May-2025	18-Jun-2025	9-Jul-2025	20-Aug-2025	2-Sep-2025	
	Water temperature	11.0	13.6	17.7	20.3	22.4	23.9	(°C)
1	Common Bacteria	< 1	< 1	< 1	< 1	< 1	< 1	(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	(MPN/100mL)
3	Cadmium		< 0.0003			< 0.0003		(mg/L)
4	Mercury		< 0.00005			< 0.00005		(mg/L)
5	Selenium	< 0.001			< 0.001			(mg/L)
6	Lead			< 0.001			< 0.001	(mg/L)
7	Arsenic	< 0.001			< 0.001			(mg/L)
8	Chromium (VI)	< 0.002			< 0.002			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			< 0.001	(mg/L)
11	Nitrate and Nitrite	0.3	0.2	0.2	0.2	0.2	0.2	(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	(mg/L)
13	Boron			< 0.1			< 0.1	(mg/L)
14	Carbon tetrachloride			< 0.0002			< 0.0002	(mg/L)
15	1, 4-dioxane	< 0.005			< 0.005			(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene			< 0.004			< 0.004	(mg/L)
17	Dichloromethane			< 0.002			< 0.002	(mg/L)
18	Tetrachloroethylene			< 0.001			< 0.001	(mg/L)
19	Trichloroethylene			< 0.001			< 0.001	(mg/L)
20	Benzene			< 0.001			< 0.001	(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06	< 0.06	0.06	0.06	(mg/L)
22	Chloroacetic acid							(mg/L)
23	Chloroform			0.007			0.016	(mg/L)
24	Dichloroacetic acid							(mg/L)
25	Dibromochloromethane			0.001			< 0.001	(mg/L)
26	Bromate			< 0.001			< 0.001	(mg/L)
27	Total trihalomethanes			0.011			0.025	(mg/L)
28	Trichloroacetic acid							(mg/L)
29	Bromodichloromethane			0.004			0.007	(mg/L)
30	Bromoform			< 0.001			< 0.001	(mg/L)
31	Formaldehyde							(mg/L)
32	Zinc			< 0.01			< 0.01	(mg/L)
33	Aluminium	0.02	0.02	0.03	0.04	0.05	0.07	(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	(mg/L)
36	Sodium	4.3	3.4	3.7	4.2	5.1	5.3	(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	(mg/L)
38	Chloride ion	5.9	4.1	4.6	4.6	5.7	6.0	(mg/L)
39	Calcium, Magnesium (Hardness)	20	21	23	24	27	30	(mg/L)
40	Total residue	48			46			(mg/L)
41	Anionic surface active agent	< 0.02			< 0.02			(mg/L)
42	Geosmin			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
43	2-Methylisobolneol			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
44	Nonionic surface active agent	< 0.005			< 0.005			(mg/L)
45	Phenols		< 0.0005			< 0.0005		(mg/L)
46	Organic substances (Total Organic Carbon)	< 0.3	< 0.3	0.3	0.4	0.5	0.5	(mg/L)
47	pH Value	7.3	7.4	7.3	7.4	7.4	7.5	
48	Taste	None	None	None	None	None	None	
49	Odor	None	None	None	None	None	None	
50	Color	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	(degree)
51	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	(degree)
	Free residual chlorine ※2	0.42	0.40	0.42	0.48	0.44	0.46	(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine $\geq$ 0.1 mg/L

Water Quality Tests Results

(Purified Water of Shijima-naka Water Distribution Plant)

No.	Items	Purified Water of Shijima-naka Water Distribution Plant						Unit
		8-Oct-2025	19-Nov-2025					
	Water temperature	17.0	11.2					(°C)
1	Common Bacteria	< 1	< 1					(number/mL)
2	E.coli	N.D. ※1	N.D. ※1					(MPN/100mL)
3	Cadmium		< 0.0003					(mg/L)
4	Mercury		< 0.00005					(mg/L)
5	Selenium	< 0.001						(mg/L)
6	Lead							(mg/L)
7	Arsenic	< 0.001						(mg/L)
8	Chromium (VI)	< 0.002						(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004					(mg/L)
10	Cyanide ion and Cyanogens chloride							(mg/L)
11	Nitrate and Nitrite	0.3	0.3					(mg/L)
12	Fluoride	< 0.08	< 0.08					(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride							(mg/L)
15	1, 4-dioxane	< 0.005						(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene							(mg/L)
17	Dichloromethane							(mg/L)
18	Tetrachloroethylene							(mg/L)
19	Trichloroethylene							(mg/L)
20	Benzene							(mg/L)
21	Chlorate	< 0.06	< 0.06					(mg/L)
22	Chloroacetic acid							(mg/L)
23	Chloroform							(mg/L)
24	Dichloroacetic acid							(mg/L)
25	Dibromochloromethane							(mg/L)
26	Bromate							(mg/L)
27	Total trihalomethanes							(mg/L)
28	Trichloroacetic acid							(mg/L)
29	Bromodichloromethane							(mg/L)
30	Bromoform							(mg/L)
31	Formaldehyde							(mg/L)
32	Zinc							(mg/L)
33	Aluminium	0.03	0.05					(mg/L)
34	Iron	< 0.03	< 0.03					(mg/L)
35	Copper	< 0.01	< 0.01					(mg/L)
36	Sodium	5.6	6.2					(mg/L)
37	Manganese	< 0.001	< 0.001					(mg/L)
38	Chloride ion	7.2	6.5					(mg/L)
39	Calcium, Magnesium (Hardness)	28	33					(mg/L)
40	Total residue	71						(mg/L)
41	Anionic surface active agent	< 0.02						(mg/L)
42	Geosmin	< 0.000001	< 0.000001					(mg/L)
43	2-Methylisobolneol	< 0.000001	< 0.000001					(mg/L)
44	Nonionic surface active agent	< 0.005						(mg/L)
45	Phenols		< 0.0005					(mg/L)
46	Organic substances (Total Organic Carbon)	0.4	0.5					(mg/L)
47	pH Value	7.4	7.7					
48	Taste	None	None					
49	Odor	None	None					
50	Color	< 0.5	< 0.5					(degree)
51	Turbidity	< 0.1	< 0.1					(degree)
	Free residual chlorine ※2	0.44	0.40					(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥ 0.1 mg/L