

Water Quality Tests Results (Izumino-machi)

No.	Items	Izumino-machi						Unit
		30-Apr-2025	14-May-2025	24-Jun-2025	16-Jul-2025	27-Aug-2025	9-Sep-2025	
	Water temperature	13.4	14.7	18.2	22.4	23.7	23.2	(°C)
1	Common Bacteria	< 1	< 1	< 1	< 1	< 1	< 1	(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	(MPN/100mL)
3	Cadmium							(mg/L)
4	Mercury							(mg/L)
5	Selenium							(mg/L)
6	Lead			< 0.001			< 0.001	(mg/L)
7	Arsenic							(mg/L)
8	Chromium (VI)	< 0.002			< 0.002			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			< 0.001	(mg/L)
11	Nitrate and Nitrite	0.3	0.2	0.2	0.3	0.4	0.3	(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride			< 0.0002			< 0.0002	(mg/L)
15	1, 4-dioxane							(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene			< 0.004			< 0.004	(mg/L)
17	Dichloromethane			< 0.002			< 0.002	(mg/L)
18	Tetrachloroethylene			< 0.001			< 0.001	(mg/L)
19	Trichloroethylene			< 0.001			< 0.001	(mg/L)
20	Benzene			< 0.001			< 0.001	(mg/L)
21	Chlorate	< 0.06	< 0.06	0.06	0.08	0.10	0.12	(mg/L)
22	Chloroacetic acid			< 0.002			< 0.002	(mg/L)
23	Chloroform			0.008			0.012	(mg/L)
24	Dichloroacetic acid			0.005			0.004	(mg/L)
25	Dibromochloromethane			< 0.001			< 0.001	(mg/L)
26	Bromate			< 0.001			< 0.001	(mg/L)
27	Total trihalomethanes			0.012			0.018	(mg/L)
28	Trichloroacetic acid			0.004			0.005	(mg/L)
29	Bromodichloromethane			0.003			0.005	(mg/L)
30	Bromoform			< 0.001			< 0.001	(mg/L)
31	Formaldehyde			< 0.008			< 0.008	(mg/L)
32	Zinc			< 0.01			< 0.01	(mg/L)
33	Aluminium	< 0.01	< 0.01	0.02	0.03	0.03	0.04	(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	(mg/L)
36	Sodium	4.9	4.5	3.9	5.1	5.1	6.0	(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	(mg/L)
38	Chloride ion	5.4	5.3	4.2	4.9	4.6	5.4	(mg/L)
39	Calcium, Magnesium (Hardness)	16	16	18	24	23	30	(mg/L)
40	Total residue	31			39			(mg/L)
41	Anionic surface active agent							(mg/L)
42	Geosmin			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
43	2-Methylisoborneol			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
44	Nonionic surface active agent							(mg/L)
45	Phenols							(mg/L)
46	Organic substances (Total Organic Carbon)	< 0.3	< 0.3	0.3	0.5	0.5	0.5	(mg/L)
47	pH Value	7.4	7.4	7.4	7.4	7.4	7.5	
48	Taste	None	None	None	None	None	None	
49	Odor	None	None	None	None	None	None	
50	Color	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	(degree)
51	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	(degree)
	Free residual chlorine ※2	0.46	0.52	0.48	0.48	0.48	0.52	(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥0.1 mg/L

Water Quality Tests Results (Izumino-machi)

No.	Items	Izumino-machi						Unit
		2-Oct-2025	11-Nov-2025					
	Water temperature	21.9	13.9					(°C)
1	Common Bacteria	< 1	< 1					(number/mL)
2	E.coli	N.D. ※1	N.D. ※1					(MPN/100mL)
3	Cadmium							(mg/L)
4	Mercury							(mg/L)
5	Selenium							(mg/L)
6	Lead							(mg/L)
7	Arsenic							(mg/L)
8	Chromium (VI)	< 0.002						(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004					(mg/L)
10	Cyanide ion and Cyanogens chloride							(mg/L)
11	Nitrate and Nitrite	0.4	0.4					(mg/L)
12	Fluoride	< 0.08	< 0.08					(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride							(mg/L)
15	1, 4-dioxane							(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2-Dichloroethylene							(mg/L)
17	Dichloromethane							(mg/L)
18	Tetrachloroethylene							(mg/L)
19	Trichloroethylene							(mg/L)
20	Benzene							(mg/L)
21	Chlorate	0.13	0.06					(mg/L)
22	Chloroacetic acid							(mg/L)
23	Chloroform							(mg/L)
24	Dichloroacetic acid							(mg/L)
25	Dibromochloromethane							(mg/L)
26	Bromate							(mg/L)
27	Total trihalomethanes							(mg/L)
28	Trichloroacetic acid							(mg/L)
29	Bromodichloromethane							(mg/L)
30	Bromoform							(mg/L)
31	Formaldehyde							(mg/L)
32	Zinc							(mg/L)
33	Aluminium	0.03	0.01					(mg/L)
34	Iron	< 0.03	< 0.03					(mg/L)
35	Copper	< 0.01	< 0.01					(mg/L)
36	Sodium	5.5	5.7					(mg/L)
37	Manganese	< 0.001	< 0.001					(mg/L)
38	Chloride ion	5.3	6.0					(mg/L)
39	Calcium, Magnesium (Hardness)	25	25					(mg/L)
40	Total residue	46						(mg/L)
41	Anionic surface active agent							(mg/L)
42	Geosmin	< 0.000001	< 0.000001					(mg/L)
43	2-Methylisoborneol	< 0.000001	< 0.000001					(mg/L)
44	Nonionic surface active agent							(mg/L)
45	Phenols							(mg/L)
46	Organic substances (Total Organic Carbon)	0.8	0.3					(mg/L)
47	pH Value	7.4	7.4					
48	Taste	None	None					
49	Odor	None	None					
50	Color	< 0.5	< 0.5					(degree)
51	Turbidity	< 0.1	< 0.1					(degree)
	Free residual chlorine ※2	0.40	0.52					(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥ 0.1 mg/L