

## Water Quality Tests Results

(Purified Water of Sue Water Purification Plant (Rapid sand filtration method))

No.	Items	Purified Water of Sue Water Purification Plant (Rapid sand filtration method)						Unit
		23-Apr-2025	29-May-2025	18-Jun-2025	9-Jul-2025	20-Aug-2025	2-Sep-2025	
	Water temperature	9.1	11.0	13.7	18.1	19.8	20.9	( °C )
1	Common Bacteria	< 1	< 1	< 1	< 1	< 1	< 1	(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1	(MPN/100mL)
3	Cadmium		< 0.0003			< 0.0003		(mg/L)
4	Mercury		< 0.00005			< 0.00005		(mg/L)
5	Selenium	< 0.001			< 0.001			(mg/L)
6	Lead			< 0.001			< 0.001	(mg/L)
7	Arsenic	< 0.001			< 0.001			(mg/L)
8	Chromium (VI)	< 0.002			< 0.002			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			< 0.001	(mg/L)
11	Nitrate and Nitrite	0.3	0.2	0.2	0.3	0.4	0.3	(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	(mg/L)
13	Boron			< 0.1			< 0.1	(mg/L)
14	Carbon tetrachloride			< 0.0002			< 0.0002	(mg/L)
15	1, 4-dioxane	< 0.005			< 0.005			(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2-Dichloroethylene			< 0.004			< 0.004	(mg/L)
17	Dichloromethane			< 0.002			< 0.002	(mg/L)
18	Tetrachloroethylene			< 0.001			< 0.001	(mg/L)
19	Trichloroethylene			< 0.001			< 0.001	(mg/L)
20	Benzene			< 0.001			< 0.001	(mg/L)
21	Chlorate	< 0.06	< 0.06	0.06	0.09	0.12	0.12	(mg/L)
22	Chloroacetic acid							(mg/L)
23	Chloroform			0.004			0.006	(mg/L)
24	Dichloroacetic acid							(mg/L)
25	Dibromochloromethane			< 0.001			< 0.001	(mg/L)
26	Bromate			< 0.001			< 0.001	(mg/L)
27	Total trihalomethanes			0.006			0.009	(mg/L)
28	Trichloroacetic acid							(mg/L)
29	Bromodichloromethane			0.001			0.002	(mg/L)
30	Bromoform			< 0.001			< 0.001	(mg/L)
31	Formaldehyde							(mg/L)
32	Zinc			< 0.01			< 0.01	(mg/L)
33	Aluminium	< 0.01	0.01	0.02	0.03	0.04	0.04	(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	< 0.03	(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	(mg/L)
36	Sodium	4.9	4.0	4.5	4.9	5.5	5.8	(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001	(mg/L)
38	Chloride ion	6.7	4.7	4.9	4.7	5.0	5.2	(mg/L)
39	Calcium, Magnesium (Hardness)	14	16	16	23	21	27	(mg/L)
40	Total residue	33			27			(mg/L)
41	Anionic surface active agent	< 0.02			< 0.02			(mg/L)
42	Geosmin			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
43	2-Methylisobolneol			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
44	Nonionic surface active agent	< 0.005			< 0.005			(mg/L)
45	Phenols		< 0.0005			< 0.0005		(mg/L)
46	Organic substances (Total Organic Carbon)	< 0.3	< 0.3	0.4	0.4	0.5	0.7	(mg/L)
47	pH Value	7.3	7.3	7.3	7.4	7.3	7.4	
48	Taste	None	None	None	None	None	None	
49	Odor	None	None	None	None	None	None	
50	Color	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	< 0.5	( degree )
51	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	( degree )
	Free residual chlorine ※2	0.56	0.54	0.56	0.66	0.74	0.72	(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine  $\geq$  0.1 mg/L

**Water Quality Tests Results**  
(Purified Water of Sue Water Purification Plant (Rapid sand filtration method))

No.	Items	Purified Water of Sue Water Purification Plant (Rapid sand filtration method)					Unit
		8-Oct-2025	19-Nov-2025	24-Dec-2025	14-Jan-2026		
	Water temperature	17.4	9.7	7.2	4.5		( °C )
1	Common Bacteria	< 1	< 1	< 1	< 1		(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1		(MPN/100mL)
3	Cadmium		< 0.0003				(mg/L)
4	Mercury		< 0.00005				(mg/L)
5	Selenium	< 0.001			< 0.001		(mg/L)
6	Lead			< 0.001			(mg/L)
7	Arsenic	< 0.001			< 0.001		(mg/L)
8	Chromium (VI)	< 0.002			< 0.002		(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004		(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			(mg/L)
11	Nitrate and Nitrite	0.3	0.3	0.3	0.4		(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08		(mg/L)
13	Boron			< 0.1			(mg/L)
14	Carbon tetrachloride			< 0.0002			(mg/L)
15	1, 4-dioxane	< 0.005			< 0.005		(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2-Dichloroethylene			< 0.004			(mg/L)
17	Dichloromethane			< 0.002			(mg/L)
18	Tetrachloroethylene			< 0.001			(mg/L)
19	Trichloroethylene			< 0.001			(mg/L)
20	Benzene			< 0.001			(mg/L)
21	Chlorate	0.10	< 0.06	< 0.06	< 0.06		(mg/L)
22	Chloroacetic acid						(mg/L)
23	Chloroform			< 0.001			(mg/L)
24	Dichloroacetic acid						(mg/L)
25	Dibromochloromethane			< 0.001			(mg/L)
26	Bromate			< 0.001			(mg/L)
27	Total trihalomethanes			0.003			(mg/L)
28	Trichloroacetic acid						(mg/L)
29	Bromodichloromethane			< 0.001			(mg/L)
30	Bromoform			< 0.001			(mg/L)
31	Formaldehyde						(mg/L)
32	Zinc			< 0.01			(mg/L)
33	Aluminium	0.04	0.01	0.01	0.01		(mg/L)
34	Iron	< 0.03	< 0.03	< 0.03	< 0.03		(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01		(mg/L)
36	Sodium	5.7	5.0	4.9	5.5		(mg/L)
37	Manganese	< 0.001	< 0.001	< 0.001	< 0.001		(mg/L)
38	Chloride ion	5.0	5.8	6.7	8.0		(mg/L)
39	Calcium, Magnesium (Hardness)	26	24	24	25		(mg/L)
40	Total residue	53			52		(mg/L)
41	Anionic surface active agent	< 0.02			< 0.02		(mg/L)
42	Geosmin	< 0.000001	< 0.000001				(mg/L)
43	2-Methylisobolneol	< 0.000001	< 0.000001				(mg/L)
44	Nonionic surface active agent	< 0.005			< 0.005		(mg/L)
45	Phenols		< 0.0005				(mg/L)
46	Organic substances (Total Organic Carbon)	0.5	0.4	< 0.3	< 0.3		(mg/L)
47	pH Value	7.5	7.4	7.3	7.3		
48	Taste	None	None	None	None		
49	Odor	None	None	None	None		
50	Color	< 0.5	< 0.5	< 0.5	< 0.5		( degree )
51	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1		( degree )
	Free residual chlorine ※2	0.68	0.62	0.62	0.46		(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine  $\geq$  0.1 mg/L