

Water Quality Tests Results (Source Water of Sue Water Purification Plant)

No.	Items	Source Water of Sue Water Purification Plant						Unit
		23-Apr-2025	29-May-2025	18-Jun-2025	9-Jul-2025	20-Aug-2025	2-Sep-2025	
	Water temperature	8.6	11.2	13.7	17.9	19.0	20.0	(°C)
1	Common Bacteria	9	15	35	280	55	60	(number/mL)
2	E.coli	2.0	12	50	390	5.2	13	(MPN/100mL)
3	Cadmium		< 0.0003			< 0.0003		(mg/L)
4	Mercury		< 0.00005			< 0.00005		(mg/L)
5	Selenium	< 0.001			< 0.001			(mg/L)
6	Lead			< 0.001			< 0.001	(mg/L)
7	Arsenic	< 0.001			0.001			(mg/L)
8	Chromium (VI)	< 0.002			< 0.002			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			< 0.001	(mg/L)
11	Nitrate and Nitrite	0.3	0.2	0.2	0.5	0.4	0.3	(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	(mg/L)
13	Boron			< 0.1			< 0.1	(mg/L)
14	Carbon tetrachloride			< 0.0002			< 0.0002	(mg/L)
15	1, 4-dioxane	< 0.005			< 0.005			(mg/L)
16	<i>cis</i> -1,2-Dichloroethylene and <i>trans</i> -1,2-Dichloroethylene			< 0.004			< 0.004	(mg/L)
17	Dichloromethane			< 0.002			< 0.002	(mg/L)
18	Tetrachloroethylene			< 0.001			< 0.001	(mg/L)
19	Trichloroethylene			< 0.001			< 0.001	(mg/L)
20	Benzene			< 0.001			< 0.001	(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	(mg/L)
22	Chloroacetic acid							(mg/L)
23	Chloroform			< 0.001			< 0.001	(mg/L)
24	Dichloroacetic acid							(mg/L)
25	Dibromochloromethane			< 0.001			< 0.001	(mg/L)
26	Bromate			< 0.001			< 0.001	(mg/L)
27	Total trihalomethanes			< 0.001			< 0.001	(mg/L)
28	Trichloroacetic acid							(mg/L)
29	Bromodichloromethane			< 0.001			< 0.001	(mg/L)
30	Bromoform			< 0.001			< 0.001	(mg/L)
31	Formaldehyde							(mg/L)
32	Zinc			< 0.01			< 0.01	(mg/L)
33	Aluminium	0.13	0.16	0.36	0.10	0.20	0.05	(mg/L)
34	Iron	0.06	0.07	0.11	0.08	0.12	0.08	(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	(mg/L)
36	Sodium	3.1	2.8	2.8	3.8	3.8	4.5	(mg/L)
37	Manganese	0.005	0.010	0.071	0.013	0.016	0.015	(mg/L)
38	Chloride ion	3.6	2.5	2.3	2.8	2.6	3.0	(mg/L)
39	Calcium, Magnesium (Hardness)	15	17	17	23	23	29	(mg/L)
40	Total residue	27			23			(mg/L)
41	Anionic surface active agent	< 0.02			< 0.02			(mg/L)
42	Geosmin			< 0.000001	0.000001	< 0.000001	< 0.000001	(mg/L)
43	2-Methylisobolneol			< 0.000001	< 0.000001	< 0.000001	< 0.000001	(mg/L)
44	Nonionic surface active agent	< 0.005			< 0.005			(mg/L)
45	Phenols		< 0.0005			< 0.0005		(mg/L)
46	Organic substances (Total Organic Carbon)	0.5	0.8	1.2	1.1	1.2	0.9	(mg/L)
47	pH Value	7.4	7.5	7.3	7.4	7.3	7.3	
48	Taste							
49	Odor	None	None	None	None	None	None	
50	Color	3	3	6	6	7	5	(degree)
51	Turbidity	4.3	4.0	9.2	3.9	3.9	1.7	(degree)
	Free residual chlorine							(mg/L)

※1 N.D. = Not detected

Water Quality Tests Results (Source Water of Sue Water Purification Plant)

No.	Items	Source Water of Sue Water Purification Plant					Unit
		8-Oct-2025	19-Nov-2025	24-Dec-2025	14-Jan-2026	5-Feb-2026	
	Water temperature	17.3	9.1	7.5	4.4	4.0	(°C)
1	Common Bacteria	35	13	8	3	2	(number/mL)
2	E.coli	23	140	16	1.0	11	(MPN/100mL)
3	Cadmium		< 0.0003			< 0.0003	(mg/L)
4	Mercury		< 0.00005			< 0.00005	(mg/L)
5	Selenium	< 0.001			< 0.001		(mg/L)
6	Lead			< 0.001			(mg/L)
7	Arsenic	0.001			< 0.001		(mg/L)
8	Chromium (VI)	< 0.002			< 0.002		(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001			(mg/L)
11	Nitrate and Nitrite	0.4	0.3	0.4	0.4	0.4	(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08	< 0.08	(mg/L)
13	Boron			< 0.1			(mg/L)
14	Carbon tetrachloride			< 0.0002			(mg/L)
15	1, 4-dioxane	< 0.005			< 0.005		(mg/L)
16	<i>cis</i> -1,2-Dichloroethylene and <i>trans</i> -1,2-Dichloroethylene			< 0.004			(mg/L)
17	Dichloromethane			< 0.002			(mg/L)
18	Tetrachloroethylene			< 0.001			(mg/L)
19	Trichloroethylene			< 0.001			(mg/L)
20	Benzene			< 0.001			(mg/L)
21	Chlorate	< 0.06	< 0.06	< 0.06	< 0.06	< 0.06	(mg/L)
22	Chloroacetic acid						(mg/L)
23	Chloroform			< 0.001			(mg/L)
24	Dichloroacetic acid						(mg/L)
25	Dibromochloromethane			< 0.001			(mg/L)
26	Bromate			< 0.001			(mg/L)
27	Total trihalomethanes			< 0.001			(mg/L)
28	Trichloroacetic acid						(mg/L)
29	Bromodichloromethane			< 0.001			(mg/L)
30	Bromoform			< 0.001			(mg/L)
31	Formaldehyde						(mg/L)
32	Zinc			< 0.01			(mg/L)
33	Aluminium	0.06	0.04	0.05	0.04	0.02	(mg/L)
34	Iron	0.07	0.06	0.03	0.03	0.03	(mg/L)
35	Copper	< 0.01	< 0.01	< 0.01	< 0.01	< 0.01	(mg/L)
36	Sodium	4.3	4.3	4.4	4.8	4.9	(mg/L)
37	Manganese	0.014	0.018	0.006	0.005	0.007	(mg/L)
38	Chloride ion	2.9	3.7	4.6	5.9	5.7	(mg/L)
39	Calcium, Magnesium (Hardness)	27	26	24	26	28	(mg/L)
40	Total residue	53			32		(mg/L)
41	Anionic surface active agent	< 0.02			< 0.02		(mg/L)
42	Geosmin	< 0.000001	< 0.000001				(mg/L)
43	2-Methylisoborneol	< 0.000001	< 0.000001				(mg/L)
44	Nonionic surface active agent	< 0.005			< 0.005		(mg/L)
45	Phenols		< 0.0005			< 0.0005	(mg/L)
46	Organic substances (Total Organic Carbon)	0.9	0.6	0.5	0.4	0.4	(mg/L)
47	pH Value	7.4	7.5	7.5	7.3	7.4	
48	Taste						
49	Odor	None	None	None	None	None	
50	Color	4	3	2	2	1	(degree)
51	Turbidity	1.8	1.5	1.2	1.5	0.8	(degree)
	Free residual chlorine						(mg/L)

※1 N.D. = Not detected