

Water Quality Tests Results (Izumino-machi)

No.	Items	Izumino-machi						Unit
		2-Apr-2026	7-May-2026					
	Water temperature	11.3	15.9					(°C)
1	Common Bacteria	< 1	< 1					(number/mL)
2	E.coli	N.D. ※1	N.D. ※1					(MPN/100mL)
3	Cadmium							(mg/L)
4	Mercury							(mg/L)
5	Selenium							(mg/L)
6	Lead							(mg/L)
7	Arsenic							(mg/L)
8	Chromium (VI)	< 0.002						(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004					(mg/L)
10	Cyanide ion and Cyanogens chloride							(mg/L)
11	Nitrate and Nitrite	0.3	0.2					(mg/L)
12	Fluoride	< 0.08	< 0.08					(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride							(mg/L)
15	1, 4-dioxane							(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene							(mg/L)
17	Dichloromethane							(mg/L)
18	Tetrachloroethylene							(mg/L)
19	Trichloroethylene							(mg/L)
20	Perfluoro(octane-1-sulfonic acid)(PFOS) and Perfluorooctanoic acid(PFOA)	< 0.000005						(mg/L)
21	Benzene							(mg/L)
22	Chlorate	< 0.06	< 0.06					(mg/L)
23	Chloroacetic acid							(mg/L)
24	Chloroform							(mg/L)
25	Dichloroacetic acid							(mg/L)
26	Dibromochloromethane							(mg/L)
27	Bromate							(mg/L)
28	Total trihalomethanes							(mg/L)
29	Trichloroacetic acid							(mg/L)
30	Bromodichloromethane							(mg/L)
31	Bromoform							(mg/L)
32	Formaldehyde							(mg/L)
33	Zinc							(mg/L)
34	Aluminium	0.01	0.02					(mg/L)
35	Iron	< 0.03	< 0.03					(mg/L)
36	Copper	< 0.01	< 0.01					(mg/L)
37	Sodium	4.7	5.0					(mg/L)
38	Manganese	< 0.001	< 0.001					(mg/L)
39	Chloride ion	5.9	4.7					(mg/L)
40	Calcium, Magnesium (Hardness)	19	18					(mg/L)
41	Total residue	36						(mg/L)
42	Anionic surface active agent							(mg/L)
43	Geosmin							(mg/L)
44	2-Methylisobolneol							(mg/L)
45	Nonionic surface active agent							(mg/L)
46	Phenols							(mg/L)
47	Organic substances (Total Organic Carbon)	< 0.3	0.4					
48	pH Value	7.3	7.3					
49	Taste	None	None					
50	Odor	None	None					
51	Color	< 0.5	< 0.5					(degree)
52	Turbidity	< 0.1	< 0.1					(degree)
	Free residual chlorine	0.42	0.40					(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥0.1 mg/L