

Water Quality Tests Results

(Source Water of Saigawa Water Purification Plant)

No.	Items	Source Water of Saigawa Water Purification Plant						Unit
		21-Apr-2026	19-May-2026	24-Jun-2026				
	Water temperature	11.3	13.1	16.1				(°C)
1	Common Bacteria	80	11	41				(number/mL)
2	E.coli	190	85	25				(MPN/100mL)
3	Cadmium		< 0.0003					(mg/L)
4	Mercury		< 0.00005					(mg/L)
5	Selenium	< 0.001						(mg/L)
6	Lead			< 0.001				(mg/L)
7	Arsenic	< 0.001						(mg/L)
8	Chromium (VI)	< 0.002						(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004				(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001				(mg/L)
11	Nitrate and Nitrite	0.3	0.3	0.3				(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08				(mg/L)
13	Boron			< 0.1				(mg/L)
14	Carbon tetrachloride			< 0.0002				(mg/L)
15	1, 4-dioxane	< 0.005						(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene			< 0.004				(mg/L)
17	Dichloromethane			< 0.002				(mg/L)
18	Tetrachloroethylene			< 0.001				(mg/L)
19	Trichloroethylene			< 0.001				(mg/L)
20	Perfluoro(octane 1-sulfonic acid)(PFOS) and Perfluorooctanoic acid(PFOA)	< 0.000005						(mg/L)
21	Benzene			< 0.001				(mg/L)
22	Chlorate	< 0.06	< 0.06	< 0.06				(mg/L)
23	Chloroacetic acid							(mg/L)
24	Chloroform			< 0.001				(mg/L)
25	Dichloroacetic acid							(mg/L)
26	Dibromochloromethane			< 0.001				(mg/L)
27	Bromate			< 0.001				(mg/L)
28	Total trihalomethanes			< 0.001				(mg/L)
29	Trichloroacetic acid							(mg/L)
30	Bromodichloromethane			< 0.001				(mg/L)
31	Bromoform			< 0.001				(mg/L)
32	Formaldehyde							(mg/L)
33	Zinc			< 0.01				(mg/L)
34	Aluminium	0.20	0.04	0.06				(mg/L)
35	Iron	0.11	0.03	0.04				(mg/L)
36	Copper	< 0.01	< 0.01	< 0.01				(mg/L)
37	Sodium	5.8	7.1	6.4				(mg/L)
38	Manganese	0.015	0.003	0.004				(mg/L)
39	Chloride ion	4.9	5.6	4.4				(mg/L)
40	Calcium, Magnesium (Hardness)	17	22	21				(mg/L)
41	Total residue	54						(mg/L)
42	Anionic surface active agent	< 0.02						(mg/L)
43	Geosmin			< 0.000001				(mg/L)
44	2-Methylisoborneol			< 0.000001				(mg/L)
45	Nonionic surface active agent	< 0.005						(mg/L)
46	Phenols		< 0.0005					(mg/L)
47	Organic substances (Total Organic Carbon)	0.8	0.6	0.8				
48	pH Value	7.3	7.4	7.4				
49	Taste							
50	Odor	None	None	None				
51	Color	3	3	4				(degree)
52	Turbidity	6.8	1.6	2.1				(degree)
	Free residual chlorine							(mg/L)

※1 N.D. = Not detected