

Water Quality Tests Results (Hikarigaoka)

No.	Items	Hikarigaoka						Unit
		2-Apr-2026	7-May-2026	30-Jun-2026	16-Jul-2026			
	Water temperature	10.5	17.7	20.8	25.8			(°C)
1	Common Bacteria	< 1	< 1	< 1	< 1			(number/mL)
2	E.coli	N.D. ※1	N.D. ※1	N.D. ※1	N.D. ※1			(MPN/100mL)
3	Cadmium							(mg/L)
4	Mercury							(mg/L)
5	Selenium							(mg/L)
6	Lead			< 0.001				(mg/L)
7	Arsenic							(mg/L)
8	Chromium (VI)	< 0.002			< 0.002			(mg/L)
9	Nitrite nitrogen	< 0.004	< 0.004	< 0.004	< 0.004			(mg/L)
10	Cyanide ion and Cyanogens chloride			< 0.001				(mg/L)
11	Nitrate and Nitrite	0.3	0.2	0.2	0.1			(mg/L)
12	Fluoride	< 0.08	< 0.08	< 0.08	< 0.08			(mg/L)
13	Boron							(mg/L)
14	Carbon tetrachloride			< 0.0002				(mg/L)
15	1, 4-dioxane							(mg/L)
16	cis-1,2-Dichloroethylene and trans-1,2- Dichloroethylene			< 0.004				(mg/L)
17	Dichloromethane			< 0.002				(mg/L)
18	Tetrachloroethylene			< 0.001				(mg/L)
19	Trichloroethylene			< 0.001				(mg/L)
20	Perfluoro(octane-1-sulfonic acid)(PFOS) and Perfluorooctanoic acid(PFOA)	< 0.000005						(mg/L)
21	Benzene			< 0.001				(mg/L)
22	Chlorate	< 0.06	< 0.06	< 0.06	< 0.06			(mg/L)
23	Chloroacetic acid			< 0.002				(mg/L)
24	Chloroform			0.012				(mg/L)
25	Dichloroacetic acid			< 0.003				(mg/L)
26	Dibromochloromethane			0.001				(mg/L)
27	Bromate			< 0.001				(mg/L)
28	Total trihalomethanes			0.018				(mg/L)
29	Trichloroacetic acid			0.010				(mg/L)
30	Bromodichloromethane			0.005				(mg/L)
31	Bromoform			< 0.001				(mg/L)
32	Formaldehyde			< 0.008				(mg/L)
33	Zinc			< 0.01				(mg/L)
34	Aluminium	0.03	0.03	0.06	0.07			(mg/L)
35	Iron	< 0.03	< 0.03	< 0.03	< 0.03			(mg/L)
36	Copper	< 0.01	< 0.01	< 0.01	< 0.01			(mg/L)
37	Sodium	5.1	4.8	5.7	5.7			(mg/L)
38	Manganese	< 0.001	< 0.001	< 0.001	< 0.001			(mg/L)
39	Chloride ion	7.0	5.2	5.8	5.4			(mg/L)
40	Calcium, Magnesium (Hardness)	26	26	25	28			(mg/L)
41	Total residue	61			55			(mg/L)
42	Anionic surface active agent							(mg/L)
43	Geosmin			< 0.000001	< 0.000001			(mg/L)
44	2-Methylisobolneol			< 0.000001	< 0.000001			(mg/L)
45	Nonionic surface active agent							(mg/L)
46	Phenols							(mg/L)
47	Organic substances (Total Organic Carbon)	0.3	0.3	0.5	0.5			
48	pH Value	7.5	7.4	7.6	7.6			
49	Taste	None	None	None	None			
50	Odor	None	None	None	None			
51	Color	< 0.5	< 0.5	< 0.5	< 0.5			(degree)
52	Turbidity	< 0.1	< 0.1	< 0.1	< 0.1			(degree)
	Free residual chlorine	0.40	0.34	0.28	0.30			(mg/L)

※1 N.D. = Not detected

※2 Necessary sanitation measures: Free residual chlorine ≥0.1 mg/L